



*WATER QUALITY SAMPLING STATION	
1	ALUMINUM LID
2	ALUMINUM HOUSING - 6"x48"
3	FLUSH MOUNTED LOCK
4	BALL VALVE, 1/2"x3/8", 400 P.S.I.

*ONLY ITEMS
1 THRU 4
INCLUDED

DETAIL NO.
G-3370

CITY OF GOODYEAR
STANDARD DETAIL

APPROVED BY:
Goodyear Standards and
Policies Committee 7/97

WATER QUALITY SAMPLING STATION

DETAIL NO.
G-3370